intertek
caleb brett

Report of Analysis

Jorge Lasso
Terpel - Petrolera Nacional
Terpel Panamá
Torre Plaza Edsin, piso 11
Panama City, Panama

Laboratory Report ID : 3058202
Job No. : 2018-PANA-000410
Client Reference : N/A

Sample ID : 2018-PANA-000410-002
Product : DIESEL LIVIANO
Sampling Point : No Especificado
Job Location : No Especificado
Representing : ***Submitted Sample : Prestripping Tk 02***

Date Taken : 15-May-2018
Date Submitted : 15-May-2018
Date Tested : 16-May-2018
Drawn By : Client

Method	Test	Result	Units	Specification Limit
ASTM D4052	API Gravity @ 60°F	38.9	°API	Min 32.0
ASTM D1500	ASTM Color	<1		Max 2.5
ASTM D4176	Appearance	Bright & Clear		Bright & Clear
ASTM D2709	Water and Sediment	0	Vol %	Max 0.05
ASTM D2622	Sulfur Content	8.5	mg/kg	Max 15
ASTM D93	Procedure Used	A		
	Corrected Flash Point	63.0	°C	Min 60.0
ASTM D189	Conradson Carbon Residue on 10% distillation residue	< 0.01	Wt %	Max 0.30
ASTM D482	Ash	< 0.001	Wt %	Max0.010

ICBFCA-019
Rev.01 April 2018

The information contained herein is based on laboratory tests and observations performed by Intertek. The sample was submitted by TERPEL - PETROLERA NACIONAL solely for testing. Intertek disclaims any and all liability for damage or injury which might result from the use of the information contained herein, and nothing contained herein shall constitute a guarantee, warranty on representation by Intertek with respect to the accuracy of the information, the sample, product or item described, or its suitability for use for any specific purpose.

Signed: Alsin Angelo Laboratory Manager Date: 16-May-2018

Intertek Caleb Brett Panama, Inc.
Alsin Angelo, Laboratory Manager